

2012 Drinking Water Quality Test Results SUMMARY TABLE

Lemieux Island Water Purification Plant

Physical, Microbiological, Chemical, & Radiological test results

Combined Average 2012 Water Production = 290.7 ML/d (Britannia = 150.8 ML/d + Lemieux Island = 139.9 ML/d)

Notes:

* Guidelines for Canadian Drinking Water Quality (Health Canada) & Ontario Drinking Water Standards (Ministry of Environment)

** Calculated parameter based on individual analytes

mg/L = milligram per Litre = part per million (ppm)

µg/L = microgram per Litre = part per billion (ppb)

reported value of 'nd' or '0' indicates that the substance was non-detectable (ie. below detection limit); detection limits are available upon request

-- Parameter not tested for

¹ reported value is an average of the maximum result observed in each quarter

² Health Canada Drinking Water Guideline only

³ Ontario Drinking Water Quality Standard only

Physical Tests

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
Colour	TCU	nd	3.5	--	5.0
Turbidity	NTU	0.05	0.24	--	5.0
Temperature	degree C	10.9	13.1	--	15.0
Conductivity	m-mhos/cm	133	134	--	--
Total Dissolved Solids	mg/L	--	--	--	500

Microbiological Tests

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
Total Coliforms	cfu/100mL	0	0	0	--
E.coli	cfu/100mL	0	0	0	--
Heterotrophic Plate Count (HPC)	cfu/mL	nd	13	--	500
Cryptosporidium	#/ 100 L	0	--	--	--
Giardia	#/ 100 L	0	--	--	--

Chemical - General

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
pH	log ₁₀	9.32	9.27	--	6.5 - 8.5
Alkalinity	mg/L CaCO ₃	29	30	--	30 - 500
Total chlorine (chloramine)	mg/L	2.06	1.75	0.25 - 3.00	--
Bromide	mg/L	0.0168	0.0046	--	--
Bromate	mg/L	nd	0.0004	0.01	--
Chlorite	mg/L	nd	0.00343	--	--
Chlorate	mg/L	0.10	0.1017	--	--
Chloride	mg/L	5.0	5.1	--	250
Perchlorate	mg/L	--	0.00008	--	--
Fluoride	mg/L	0.67	0.68	1.5	--
Calcium	mg/L	8.0	8.2	--	--
Magnesium	mg/L	2.1	2.0	--	--
Potassium	mg/L	0.67	0.70	--	--
Sodium	mg/L	15.2	15.2	20	200
Silicate	mg/L SiO ₂	2.43	--	--	--
Sulphate	mg/L	25.3	24.9	--	500
Phosphates	mg/L	nd	0.002	--	--
Total Phosphorous	mg/L	0.003	nd	--	--
Cyanide	mg/L	nd	nd	0.2	--
Total Hardness**	mg/L CaCO ₃	28.8	28.8	--	80 - 100
Calcium Hardness**	mg/L CaCO ₃	20.1	20.5	--	--
Magnesium Hardness**	mg/L CaCO ₃	8.5	8.3	--	--
Ammonia	mg/L N	nd	0.02	--	--
Total Kjeldahl Nitrogen	mg/L N	0.33	0.38	--	--
Organic Nitrogen**	mg/L N	0.03	0.36	--	0.15
UV254 Absorbance	Absorbance/cm	0.051	0.060	--	--
Nitrate	mg/L N	0.13	0.11	10.0	--
Nitrite	mg/L N	nd	nd	1.0	--
Total Organic Carbon	mg/L	--	--	--	--
Dissolved Organic Carbon	mg/L	2.9	3.0	--	5.0
Dissolved Inorganic Carbon	mg/L	6.0	--	--	--
Langelier's Index**	log ₁₀	0.2	0.2	--	--
C-T Disinfection**	mg/L-min	87.4	--	--	--
Log Giardia Disinfection**	log ₁₀	4.2	--	Minimum 0.5-Log	--
Log Virus Disinfection**	log ₁₀	14.9	--	Minimum 3.0-Log	--

Chemical - Inorganic Metals

2012 Drinking Water Quality Test Results SUMMARY TABLE

Lemieux Island Water Purification Plant

Physical, Microbiological, Chemical, & Radiological test results

Combined Average 2012 Water Production = 290.7 ML/d (Britannia = 150.8 ML/d + Lemieux Island = 139.9 ML/d)

Notes:

* Guidelines for Canadian Drinking Water Quality (Health Canada) & Ontario Drinking Water Standards (Ministry of Environment)

** Calculated parameter based on individual analytes

mg/L = milligram per Litre = part per million (ppm)

µg/L = microgram per Litre = part per billion (ppb)

reported value of 'nd' or '0' indicates that the substance was non-detectable (i.e. below detection limit); detection limits are available upon request

-- Parameter not tested for

¹ reported value is an average of the maximum result observed in each quarter

² Health Canada Drinking Water Guideline only

³ Ontario Drinking Water Quality Standard only

Physical Tests

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
Aluminum	mg/L	0.0582	0.0496	--	0.100
Antimony	mg/L	0.0003	0.0002	0.006	--
Arsenic	mg/L	0.0003	0.0004	0.010 ² / 0.025 ³	--
Barium	mg/L	0.0162	0.0133	1.0	--
Beryllium	mg/L	nd	nd	--	--
Bismuth	mg/L	nd	0.0002	--	--
Boron	mg/L	0.0075	0.0075	5.000	--
Cadmium	mg/L	nd	nd	0.01	--
Chromium	mg/L	0.0002	0.0006	0.05	--
Chromium VI	mg/L	0.00006		--	--
Cobalt	mg/L	nd	nd	--	--
Copper	mg/L	0.0011	0.0028	--	1.00
Iron	mg/L	0.0163	0.0192	--	0.30
Lead	mg/L	nd	nd	0.010	--
Manganese	mg/L	0.0029	0.0028	--	0.05
Mercury	mg/L	nd	nd	0.001	--
Molybdenum	mg/L	nd	0.0014	--	--
Nickel	mg/L	0.0011	0.0024	--	--
Selenium	mg/L	nd	nd	0.010	--
Silver	mg/L	nd	nd	--	--
Strontium	mg/L	0.040	0.0405	--	--
Thallium	mg/L	nd	nd	--	--
Tin	mg/L	0.0001	nd	--	--
Titanium	mg/L	nd	nd	--	--
Tungsten	mg/L	nd	0.0003	--	--
Uranium	mg/L	nd	nd	0.02	--
Vanadium	mg/L	0.0004	0.0005	--	--
Zinc	mg/L	0.0011	0.0010	--	5.0
Zirconium	mg/L	0.0001	nd	--	--

Radiological Parameters

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
Gross-Alpha Radioactivity	Bq/L	nd	--	0.10	--
Gross-Beta Radioactivity	Bq/L	0.03		1.00	--
Tritium	Bq/L	4.4	--	7000	--

Chemical - Disinfection By-Products

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
Chloroform	µg/L	22.8	24.7	--	--
Bromodichloromethane	µg/L	4.2	4.7	--	--
Dibromochloromethane	µg/L	0.6	0.6	--	--
Bromoform	µg/L	nd	nd	--	--
Total Trihalomethanes (TTHMs) ¹	µg/L	31.8	36.1	100.0	--
Monochloroacetic Acid	µg/L	nd	1.3	--	--
Monobromoacetic Acid	µg/L	nd	nd	--	--
Dichloroacetic Acid	µg/L	10.1	14.4	--	--
Dibromoacetic Acid	µg/L	nd	nd	--	--
Trichloroacetic Acid	µg/L	8.5	9.2	--	--
Bromochloroacetic Acid	µg/L	2.2	2.3	--	--
Bromodichloroacetic Acid	µg/L	2.1	2.0	--	--
Chlorodibromoacetic Acid	µg/L	nd	nd	--	--
Tribromoacetic Acid	µg/L	nd	nd	--	--

2012 Drinking Water Quality Test Results SUMMARY TABLE

Lemieux Island Water Purification Plant

Physical, Microbiological, Chemical, & Radiological test results

Combined Average 2012 Water Production = 290.7 ML/d (Britannia = 150.8 ML/d + Lemieux Island = 139.9 ML/d)

Notes:

* Guidelines for Canadian Drinking Water Quality (Health Canada) & Ontario Drinking Water Standards (Ministry of Environment)

** Calculated parameter based on individual analytes

mg/L = milligram per Litre = part per million (ppm)

µg/L = microgram per Litre = part per billion (ppb)

reported value of 'nd' or '0' indicates that the substance was non-detectable (ie. below detection limit); detection limits are available upon request

-- Parameter not tested for

¹ reported value is an average of the maximum result observed in each quarter

² Health Canada Drinking Water Guideline only

³ Ontario Drinking Water Quality Standard only

Physical Tests

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
Total Haloacetic Acids (HAA5)	µg/L	19.1	24.7	80.0 ²	--
Total Haloacetic Acids (HAA9)	µg/L	23.3	29.1		

Chemical - Trace Organic Parameters

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
1,1,1-Trichloroethane	µg/L	nd	nd	--	--
1,1,2,2-Tetrachloroethane	µg/L	nd	nd	--	--
1,1,2-Trichloroethane	µg/L	nd	nd	--	--
1,1-Dichloroethane	µg/L	nd	nd	--	--
1,1-Dichloroethylene	µg/L	nd	nd	14	--
1,2-Dibromoethane	µg/L	nd	nd	--	--
1,2-Dichlorobenzene	µg/L	nd	nd	200	--
1,2-Dichloroethane	µg/L	nd	nd	--	--
1,2-Dichloroethylene - cis	µg/L	nd	nd	--	--
1,2-Dichloroethylene - trans	µg/L	nd	nd	--	--
1,2-Dichloropropane	µg/L	nd	nd	--	--
1,3-Dichlorobenzene	µg/L	nd	nd	--	--
1,4-Dichlorobenzene	µg/L	nd	nd	5	--
2,2 -Dichloropropanoic Acid	µg/L	0.35	0.23	--	--
2,3,4,6-Tetrachlorophenol	µg/L	nd	--	100	--
2,3,6-Trichloroanisole	µg/L	nd	nd	--	--
2,4,5-Trichlorophenoxyacetic Acid (2,4,5-T)	µg/L	nd	--	280	--
2,4,6-Trichloroanisole	µg/L	nd	nd	--	--
2,4,6-Trichlorophenol	µg/L	nd	--	5	--
2,4-Dichlorophenol	µg/L	nd	--	900	--
2,4-Dichlorophenoxyacetic Acid (2,4-D)	µg/L	nd	--	100	--
2-Isobutyl-3-methoxypyrazine	µg/L	nd	nd	--	--
2-Isopropyl -3-methoxypyrazine	µg/L	nd	nd	--	--
2-Methylisoborneol	µg/L	nd	nd	--	--
Alachlor	µg/L	nd	--	5	--
Aldicarb	µg/L	nd	--	9	--
Aldrin	µg/L	nd	--	--	--
Aldrin + Dieldrin	µg/L	nd	--	1	--
Atrazine	µg/L	nd	--	--	--
Atrazine +N -dealkylated metabolites	µg/L	nd	--	5	--
Azinphos-methyl	µg/L	nd	--	20	--
Bendiocarb	µg/L	nd	--	40	--
Benzene	µg/L	nd	nd	5	--
Benzo(a)pyrene	µg/L	nd	--	0	--
Bromoxynil	µg/L	nd	--	5	--
Carbaryl	µg/L	nd	--	90	--
Carbofuran	µg/L	nd	--	90	--
Carbon Tetrachloride	µg/L	nd	nd	5	--
Chlordane - alpha	µg/L	nd	--	--	--
Chlordane - gamma	µg/L	nd	--	--	--
Chlordane - total	µg/L	nd	--	7	--
Chlorobenzene	µg/L	nd	nd	80	--
Chloroethylene (monochloroethylene)	µg/L	nd	nd	--	--
Chlorpyrifos	µg/L	nd	--	90	--
Cyanazine	µg/L	nd	--	10	--
DDD - para, para	µg/L	nd	--	--	--
DDE- para, para	µg/L	nd	--	--	--
DDT - ortho, para	µg/L	nd	--	--	--
DDT - para, para	µg/L	nd	--	--	--
DDT + metabolites	µg/L	nd	--	30	--
De-ethylated Atrazine	µg/L	nd	--	--	--

2012 Drinking Water Quality Test Results SUMMARY TABLE

Lemieux Island Water Purification Plant

Physical, Microbiological, Chemical, & Radiological test results

Combined Average 2012 Water Production = 290.7 ML/d (Britannia = 150.8 ML/d + Lemieux Island = 139.9 ML/d)

Notes:

* Guidelines for Canadian Drinking Water Quality (Health Canada) & Ontario Drinking Water Standards (Ministry of Environment)

** Calculated parameter based on individual analytes

mg/L = milligram per Litre = part per million (ppm)

µg/L = microgram per Litre = part per billion (ppb)

reported value of 'nd' or '0' indicates that the substance was non-detectable (ie. below detection limit); detection limits are available upon request

-- Parameter not tested for

¹ reported value is an average of the maximum result observed in each quarter

² Health Canada Drinking Water Guideline only

³ Ontario Drinking Water Quality Standard only

Physical Tests

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
Diazinon	µg/L	nd	--	20	--
Dicamba	µg/L	nd	--	120	--
Dichloroacetonitrile	µg/L	nd	nd	--	--
Dichloromethane	µg/L	nd	nd	50	--
Diclofop - methyl	µg/L	nd	--	9	--
Dieldrin	µg/L	nd	--	--	--
Diisopropylether	µg/L	nd	nd	--	--
Dimethoate	µg/L	nd	--	20	--
Dinoseb	µg/L	nd	--	10	--
Diquat	µg/L	nd	--	70	--
Diuron	µg/L	nd	--	150	--
Ethylbenzene	µg/L	nd	nd	--	2
Geosmin	µg/L	nd	nd	--	--
Glyphosate	µg/L	nd	--	280	--
Heptachlor	µg/L	nd	--	--	--
Heptachlor + Heptachlor Epoxide	µg/L	nd	--	3	--
Heptachlor Epoxide	µg/L	nd	--	--	--
Hexachlorocyclohexane - gamma (g-BHC, Lindane)	µg/L	nd	--	4	--
Iodoacetic Acid	µg/L	nd	nd	--	--
Malathion	µg/L	nd	--	190	--
MCPA	µg/L	nd	nd	--	--
Methoxychlor	µg/L	nd	--	900	--
Methyl-tert -Butyl ether	µg/L	nd	nd	--	--
Metolachlor	µg/L	nd	--	50	--
Metribuzin	µg/L	nd	--	80	--
N - Nitrosodi - n - propylamine	µg/L	nd	nd	--	--
N - Nitrosodibutylamine	µg/L	nd	nd	--	--
N - Nitrosodiethylamine	µg/L	nd	nd	--	--
N - Nitrosodimethylamine	µg/L	0.002	0.001	0.040 ² / 0.009 ³	--
N - Nitrosomethyllethylamine	µg/L	nd	--	--	--
N - Nitrosomorpholine	µg/L	nd	nd	--	--
N - Nitrosopiperidine	µg/L	nd	nd	--	--
N - Nitrosopyrrolidine	µg/L	nd	nd	--	--
Nitrioltriacetic Acid	µg/L	nd	nd	400	--
Oxychlorane	µg/L	nd	--	--	--
Paraquat	µg/L	nd	--	10	--
Parathion	µg/L	nd	--	50	--
Pentachlorophenol	µg/L	nd	--	60	--
Phorate	µg/L	nd	--	2	--
Picloram	µg/L	nd	--	190	--
Polychlorinated Byphenyls (PCB's)	µg/L	nd	--	3	--
Prometryne	µg/L	nd	--	1	--
Simazine	µg/L	nd	--	10	--
Styrene	µg/L	0.20	0.11	--	--
Temephos	µg/L	nd	--	280	--
Terbufos	µg/L	nd	--	1	--
Tetrachloroethylene	µg/L	nd	nd	30	--
Toluene	µg/L	nd	nd	--	24
Triallate	µg/L	nd	--	230	--
Trichloroethylene	µg/L	nd	nd	5	--
Trifluralin	µg/L	nd	--	45	--
Vinyl Chloride	µg/L	nd	--	2	--
Xylene - meta & para	µg/L	0.07	nd	--	--
Xylene - ortho	µg/L	nd	nd	--	--
Xylene - total	µg/L	0.07	nd	--	300
2,3,7,8,-Tetra-Dibenzo-p-Dioxin	µg/L	nd	--	--	--
1,2,3,7,8,-Penta-Dibenzo-p-Dioxin	µg/L	nd	--	--	--

2012 Drinking Water Quality Test Results SUMMARY TABLE

Lemieux Island Water Purification Plant

Physical, Microbiological, Chemical, & Radiological test results

Combined Average 2012 Water Production = 290.7 ML/d (Britannia = 150.8 ML/d + Lemieux Island = 139.9 ML/d)

Notes:

* Guidelines for Canadian Drinking Water Quality (Health Canada) & Ontario Drinking Water Standards (Ministry of Environment)

** Calculated parameter based on individual analytes

mg/L = milligram per Litre = part per million (ppm)

µg/L = microgram per Litre = part per billion (ppb)

reported value of 'nd' or '0' indicates that the substance was non-detectable (ie. below detection limit); detection limits are available upon request

-- Parameter not tested for

¹ reported value is an average of the maximum result observed in each quarter

² Health Canada Drinking Water Guideline only

³ Ontario Drinking Water Quality Standard only

Physical Tests

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
1,2,3,4,7,8,-Hexa-Dibenzo-p-Dioxin	µg/L	nd	--	--	--
1,2,3,6,7,8,-Hexa-Dibenzo-p-Dioxin	µg/L	nd	--	--	--
1,2,3,7,8,9-Hexa-Dibenzo-p-Dioxin	µg/L	nd	--	--	--
1,2,3,4,6,7,8,-Hepta-Dibenzo-p-Dioxin	µg/L	nd	--	--	--
2,3,7,8-Tetra-Dibenzofuran	µg/L	nd	--	--	--
1,2,3,7,8,-Penta-Dibenzofuran	µg/L	nd	--	--	--
2,3,4,7,8,-Penta-Dibenzofuran	µg/L	nd	--	--	--
1,2,3,4,7,8,-Hexa-Dibenzofuran	µg/L	nd	--	--	--
1,2,3,6,7,8,-Hexa-Dibenzofuran	µg/L	nd	--	0.000015	--
2,3,4,6,7,8,-Hexa-Dibenzofuran	µg/L	nd	--	--	--
1,2,3,7,8,9,-Hexa-Dibenzofuran	µg/L	nd	--	--	--
1,2,3,4,6,7,8-Hepta-Dibenzofuran	µg/L	nd	--	--	--
1,2,3,4,7,8,9,-Hepta-Dibenzofuran	µg/L	nd	--	--	--
Total Tetrachlorodibenzo-p-Dioxins	µg/L	nd	--	--	--
Total Pentachlorodibenzo-p-Dioxins	µg/L	nd	--	--	--
Total Hexachlorodibenzo-p-Dioxins	µg/L	nd	--	--	--
Total Heptachlorodibenzo-p-Dioxins	µg/L	nd	--	--	--
Total Octachlorodibenzo-p-Dioxins	µg/L	nd	--	--	--
Total Tetrachlorodibenzofurans	µg/L	nd	--	--	--
Total Pentachlorodibenzofurans	µg/L	nd	--	--	--
Total Hexachlorodibenzofurans	µg/L	nd	--	--	--
Total Heptachlorodibenzofurans	µg/L	nd	--	--	--
Total Octachlorodibenzofuran	µg/L	nd	--	0.000015	--
2,3,7,8-TCDD Toxicity Equivalents	TEQ/L	nd	--	0.000015	--

Pharmaceuticals & Personal Care Products (PPCPs)

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
1,7-Dimethylxanthine	µg/L	nd	--	--	--
10-Hydroxy-Amitriptyline	µg/L	nd	--	--	--
17a-Dihydroequilin	µg/L	nd	--	--	--
17a-Estradiol	µg/L	nd	--	--	--
17a-Ethinylestradiol	µg/L	nd	--	--	--
17b-Estradiol	µg/L	nd	--	--	--
2-Hydroxy-Ibuprofen	µg/L	nd	--	--	--
4-Epianhydrochlorotetracycline	µg/L	nd	--	--	--
4-Epianhydrotetracycline	µg/L	nd	--	--	--
4-Epichlorotetracycline	µg/L	nd	--	--	--
4-Epioxytetracycline	µg/L	nd	--	--	--
Acetaminophen	µg/L	nd	--	--	--
Albuterol	µg/L	0.003	--	--	--
Amitriptyline	µg/L	nd	--	--	--
Amlodipine	µg/L	nd	--	--	--
Amphetamine	µg/L	nd	--	--	--
Androstenedion	µg/L	nd	--	--	--
Androsterone	µg/L	nd	--	--	--
Anhydrotetracycline	µg/L	<	--	--	--
Atenolol	µg/L	0.005	--	--	--
Atorvastatin	µg/L	nd	--	--	--
Azithromycin	µg/L	nd	--	--	--
Benzafibrate	µg/L	nd	--	--	--
Benzoyllecgonine	µg/L	nd	--	--	--
Betamethasone	µg/L	nd	--	--	--
Caffeine	µg/L	0.004	--	--	--
Carbamazepine	µg/L	0.001	--	--	--
Ciprofloxacin	µg/L	nd	--	--	--
Clotrimazole	µg/L	nd	--	--	--

2012 Drinking Water Quality Test Results SUMMARY TABLE

Lemieux Island Water Purification Plant

Physical, Microbiological, Chemical, & Radiological test results

Combined Average 2012 Water Production = 290.7 ML/d (Britannia = 150.8 ML/d + Lemieux Island = 139.9 ML/d)

Notes:

* Guidelines for Canadian Drinking Water Quality (Health Canada) & Ontario Drinking Water Standards (Ministry of Environment)

** Calculated parameter based on individual analytes

mg/L = milligram per Litre = part per million (ppm)

µg/L = microgram per Litre = part per billion (ppb)

reported value of 'nd' or '0' indicates that the substance was non-detectable (ie. below detection limit); detection limits are available upon request

-- Parameter not tested for

¹ reported value is an average of the maximum result observed in each quarter

² Health Canada Drinking Water Guideline only

³ Ontario Drinking Water Quality Standard only

Physical Tests

Parameter	Unit of measure	Lemieux Treated Water (average)	Central Distribution (average)	Health-based Drinking Water Guideline*	Aesthetic or Operational Guideline*
Cotinine	µg/L	0.002	--	--	--
Deet	µg/L	nd	--	--	--
Diphenhydramine	µg/L	0.002	--	--	--
Enrofloxacin	µg/L	nd	--	--	--
Epitetracycline	µg/L	nd	--	--	--
Erythromycin	µg/L	0.002	--	--	--
Fluoxetine	µg/L	nd	--	--	--
Indomethacin	µg/L	nd	--	--	--
Ketoprofen	µg/L	nd	--	--	--
Metformin	µg/L	0.02	--	--	--
Miconazole	µg/L	nd	--	--	--
Norfloxacine	µg/L	nd	--	--	--
Ofloxacin	µg/L	nd	--	--	--
Oxolinic Acid	µg/L	nd	--	--	--
Pentoxifylline	µg/L	nd	--	--	--
Roxithromycin	µg/L	nd	--	--	--
Sulfachloropyridazine	µg/L	nd	--	--	--
Sulfadiazine	µg/L	nd	--	--	--
Sulfadimethoxine	µg/L	nd	--	--	--
Sulfamerazine	µg/L	nd	--	--	--
Sulfamethazine	µg/L	nd	--	--	--
Sulfamethizole	µg/L	nd	--	--	--
Sulfamethoxazole	µg/L	nd	--	--	--
Sulfathiazole	µg/L	nd	--	--	--
Trimethoprim	µg/L	nd	--	--	--